

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**


No. PH-35/22

Date: 29.6.22

It is certified that an inspection team headed by NAZEER. V.M.  
HEALTH INSPECTOR, FHC MAMBRA (Name of Officers  
with designation) from HEALTH DEPARTMENT/FHC MAMBRA (Name of  
Department/Office) inspected the VIVEKODAYAM VIDYA MANDIR  
CBSE SECONDARY SCHOOL, ANNAMARADA (Name & Address of  
the School) on 20/6/22 and found that the VIVEKODAYAM VIDYA  
MANDIR, CBSE SECONDARY SCHOOL (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

BUILDING NO- 5/13A



To

The Managers  
Vivekodayam Vidya Mandir  
CBSE Secondary School, Annamarada.  
(Name & Address of the Institution)

Signature with Seal :

Name :

NAZEER

Designation :

HEALTH INSPECTOR

FHC MAMBRA

**TEST REPORT**

Test Report No : CKL/22/T567

Date : 31-05-2022

- Name of Customer : Vivekodayam Vidhya Mandir School
- Customer Address : Annamanada-680741
- Test Requisition No. & Date : LWF220 & 26-05-2022
- Date of Sample Received : 26-05-2022
- Sample Analysis Date : 27-05-2022 To 31-05-2022
- Sample Name : Well Water
- Sample ID : T567
- Quantity of Sample Received : 900 ml
- Sample Drawn by : The Medical Officer, PHC Mambra
- Sample Condition : Received in plastic bottle

Parameters	Unit	Result	Specification	Detection Limit	Test Method
Alkalinity as CaCO <sub>3</sub>	mg/ L	67.60	Max- 200	-	IS: 3025 Part 23
Calcium	mg/ L	Nil	Max- 75	-	IS: 3025 part 40
Chloride	mg/ L	18.72	Max- 250	-	IS: 3025 part 32
Fluoride	mg/ L	Not Detected	Max- 1	-	IS: 3025 part 60
Hardness	mg/ L	Nil	Max- 200	-	IS: 3025 part 21
Iron as Fe	mg/ L	BDL	Max- 0.3	0.05	CKL/ANL/WA-021
Nitrate as NO <sub>3</sub> <sup>-</sup>	mg/ L	0.78	Max- 45	-	IS: 3025 part 34
pH	-	7.35	6.5 – 8.5	-	IS: 3025 Part 11
Sulphate as SO <sub>4</sub> <sup>2-</sup>	mg/ L	< 4	Max- 200	-	IS: 3025 part 24
Total Dissolved Solids	mg/ L	98	Max- 500	-	IS: 3025 part 16
Turbidity	NTU	< 2	Max- 5	-	IS: 3025 part 10
Acidity	mg/ L	13.20	-	-	IS: 3025 Part 22

The sample complies as per IS: 10500- 2012, with respect to the tested parameters.

BDL-Below Detection Limit

Total Number of Determination: 12 only

  
For Vivekodayam Vidya Mandir  
Annamanada

  
Authorized signatory  
CARe Lab Mandir  
CARE Kerala Ltd

Note: The test results relate only to the sample tested. The report shall not be reproduced except in full, without the written approval of the laboratory

Address: KINFRA Small Industries Park, Nalukettu road, Koratty-680309, Ph: 0480 2735837, Fax: 0480 2735737, E-mail: [lab@carekeralam.com](mailto:lab@carekeralam.com)

**TEST REPORT**

Test Report No : CKL/22/T567

Date : 30-05-2022

- Name of Customer : Vivekodayam Vidhya Mandir School
- Customer Address : Annamanada-680741
- Test Requisition No. & Date : LWF220 & 26-05-2022
- Date of Sample Received : 26-05-2022
- Sample Analysis Date : 27-05-2022 To 30-05-2022
- Sample Name : Well Water
- Sample ID : T567
- Quantity of Sample Received : 250 ml
- Sample Drawn by : The Medical Officer, PHC Mambra
- Sample Condition : Received in sterile bottle

Parameters	Unit	Result	Test Method
Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 B
<i>E.coli</i>	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 F
Fecal Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 E

Note: '< 1.8' is equivalent to 'Absent' as per Test method.

Total Number of Determination: 3 only



For Vivekodayam Vidya Mandir  
Annamanada



M. Anny



Authorized signatory  
**Sijo Varghese T.**  
(Microbiologist)

Note: The test results relate only to the sample tested. The report shall not be reproduced except in full, without the written approval of the laboratory

Address: KINFRA Small Industries Park, Nalukettu road, Koratty-680309, Ph: 0480 2735837, Fax: 0480 2735737, E-mail: [lab@carekeralam.com](mailto:lab@carekeralam.com)

സാനിറ്ററി സർട്ടിഫിക്കറ്റ്

- 1) LSGD- Circular No. 65562/ Rc 3/12/LSGD/Dt. 10.1.2013
- 2) Service -ACT No. O-M-3/30992/12/DHS/Dt.06.5.2014
- 3) No. 16203 /A-R (12) 1/2013 ഉ.ഭ.പ.വ/TVM/Dt.08.4.2014

തൃശ്ശൂർ ജില്ലയിൽ Perumams (Annamanada) പഞ്ചായത്തിൽ Annamanada പ്രദേശത്ത്  
V/134 കെട്ടിടത്തിൽ പ്രവർത്തിച്ചുവരുന്ന Vivekodayam  
Vidhya Mandir School എന്ന


സ്ഥാപനത്തിൽ 28/09/2021 തിയ്യതിയിൽ ഈ സ്ഥാപനത്തിലെ ഹെൽത്ത് ഇൻസ്പെക്ടർ  
 പരിശോധിച്ചു. ടി യൂണിറ്റ് A കുതിരശക്തിയിൽ പ്രവർത്തിക്കുന്ന

സ്ഥാപനം Manager, Vivekodayam Vidhya  
Mandir School ആളുടെ ഉടമസ്ഥയിലുമാണ്. യൂണിറ്റും പരിസ

രവവും പരിശോധിച്ചപ്പോൾ സാനിറ്ററി കണ്ടീഷൻസ് തൃപ്തികരമെന്ന് ബോധ്യമായി  
Annamanada പഞ്ചായത്തിൽ നിന്ന് ലൈസൻസിനുവേണ്ടി താഴെ പറയുന്ന വ്യവ  
 ധനകൾക്കും നിബന്ധനകൾക്കും വിധേയമായി സ്ഥാപനത്തിന് സാനിറ്ററി സർട്ടിഫിക്കറ്റ്  
 പുറപ്പെടുവിക്കുന്നു.

2021-1924

1. പൊതുജനാരോഗ്യ ശല്യമുണ്ടാകാത്തരീതിയിൽ സ്ഥാപനം പ്രവർത്തിക്കണം.
2. മാലിന്യം പൊതുജനാരോഗ്യത്തിന് ഹാനികരമാകാത്ത വിധത്തിൽ ശാസ്ത്രീയമായി സാംസ്കാരികമാക്കണം.
3. ജലസ്രോതസ്സും മറ്റും സാംക്രമികരോഗങ്ങൾ ഉണ്ടാകാത്ത വിധത്തിൽ സംരക്ഷിക്കണം.
4. ഈ സ്ഥാപനത്തിൽ നിന്നും ജലം, വായു, ശബ്ദം, മലിനീകരണം ഉണ്ടാകുന്ന പ്രവർത്തനം പാടില്ല.
5. സ്ഥാപനവും പരിസരവും സാംക്രമികരോഗങ്ങൾ ഉണ്ടാകാത്ത രീതിയിൽ ശുചിത്വം ഉറപ്പുവരുത്തേണ്ടതാണ്.
6. ജീവനക്കാർ സാംക്രമികരോഗങ്ങളിൽ നിന്നും മുക്തരായിരിക്കേണ്ടതാണ്.
7. പുകയില മുക്തം സൈൻബോർഡ് പ്രദർശിപ്പിച്ചിരിക്കേണ്ടതും സ്ഥാപനം പുകവിമുക്തമെന്ന് ഉറപ്പുവരുത്തണം.
8. അന്യസംസ്ഥാന തൊഴിലാളികൾ സ്ഥാപനത്തിൽ ഉണ്ടെങ്കിൽ അടുത്തുള്ള പ്രാഥമികാരോഗ്യകേന്ദ്രത്തിലെ മെഡിക്കൽ ഓഫീസറെ അറിയിക്കേണ്ടതാണ്.
9. പ്ലാസ്റ്റിക് മാലിന്യം പരിസരത്ത് കത്തിക്കുകയോ വലിച്ചെറിയുകയോ ചെയ്യരുത്. പ്ലാസ്റ്റിക് മാലിന്യം ശേഖരിച്ച് ശാസ്ത്രീയമായി സംസ്കരിക്കുക.
10. പൊതുജനാരോഗ്യനിയമം (MPH ACT/TCPH ACT) പഞ്ചായത്തീരാജ് നിയമവും ചട്ടങ്ങളും മറ്റ് ബന്ധപ്പെട്ട നിയമങ്ങളും നടപടിക്രമങ്ങളും പാലിച്ചിരിക്കണം.
11. ഭാവിയിൽ ഏതെങ്കിലും തരത്തിലുള്ള വികസന പ്രവർത്തനങ്ങൾക്ക് ഈ ഓഫീസിൽ നിന്നും ലബ്ധിക്കുന്ന അനുമതിക്ക് വിധേയമായിരിക്കണം.
12. മുകളിൽ പറഞ്ഞ നിബന്ധനകളിൽ ഏതെങ്കിലും പാലിക്കാതെ വന്നാൽ മറ്റൊരു അറിയിപ്പും കൂടാതെ സാനിറ്ററി സർട്ടിഫിക്കറ്റ് റദ്ദ് ചെയ്യുന്നതാണ്.



Rajakrishnan  
 MANAGER

ഹെൽത്ത് ഇൻസ്പെക്ടർ  
 പ്രാഥമികാരോഗ്യകേന്ദ്രം

Subhashini  
 ഹെൽത്ത് ഇൻസ്പെക്ടർ  
 പി.എച്ച്.സി.മാമ്പ്ര

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.

No. 358/21 dtd 30/09/2021

Date: 30/09/2021

It is certified that an inspection team headed by SHAJI J  
Health Inspector Incharge. (Name of Officers  
will designation) from FHC, Mambra, Dept. of Health Services (Name of  
Department/Office) inspected the Vivekodayam Vidhya Mandir  
School, Annamanada. V/134 (Name & Address of  
the School) on 28/09/2021 and found that the Vivekodayam Vidhya  
Mandir School, Annamanada. (Name of school) has safe-  
drinking water facilities for the students and members of staff of the institution and maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T. Govt.

The above valid for a period of One Year

Rajakthy K  
VIVEKODAYAM VIDYAMANDIR  
ANNAMANADA

Signature with Seal : [Signature]

Name : SHAJI J

Designation : JHI-Cor I


പി.എച്ച്.സി.സി.ഒ. ഇൻചേജ്  
മെമ്പർ  
വെൽഫെയർ

To  
The Manager  
Vivekodayam Vidhya Mandir School  
Annamanada.

[Signature]  
**MANAGER**

(Name & Address of the Institution)

VIVEKODAYAM VIDYAMANDIR  
ANNAMANADA - 680741



## TEST REPORT

Test Report No : CKL/21/ U888

Date : 22-09-2021

- Name of Customer : Vivekodayam Vidya Mandir School
- Customer Address : Annamanada
- Test Requisition No. & Date : LWE294 & 18-09-2021
- Date of Sample Received : 18-09-2021
- Sample Analysis Date : 20-09-2021 To 21-09-2021
- Sample Name : Well water
- Sample ID : U888
- Quantity of Sample Received : 1ltr
- Sample Drawn by : The Medical officer ,PHC Mambra
- Sample Condition : Received in 1 ltr Plastic bottle.

Parameters	Unit	Result	Specification	Test Method
Alkalinity as CaCO <sub>3</sub>	mg/ L	45.68	Max- 200	IS: 3025 Part 23
Calcium	mg/ L	Nil	Max- 75	IS: 3025
Chloride	mg/ L	12.44	Max- 250	IS: 3025 part 32
Fluoride	mg/ L	Not detected	Max- 1	IS: 3025 part 60
Hardness	mg/ L	Nil	Max- 200	IS: 3025 part 21
Iron as Fe	mg/ L	Not detected	Max- 0.3	CKL/ANL/WA-021
Nitrate as NO <sub>3</sub> <sup>-</sup>	mg/ L	2.20	Max- 45	IS: 3025 part 34
pH	-	7.43	6.5 – 8.5	IS: 3025 Part 11
Sulphate as SO <sub>4</sub> <sup>2-</sup>	mg/ L	Not detected	Max- 200	IS: 3025 part 24
Total Dissolved Solids	mg/ L	48	Max- 500	IS: 3025 part 16
Turbidity	NTU	< 2	Max- 5	IS: 3025 part 10
Acidity	mg/ L	4.24	-	IS: 3025 Part 22

The sample complies as per IS: 10500- 2012, with respect to the tested parameters.

Total Number of Determination: 12 only

*Rajalathya K.*

PRINCIPAL  
VIVEKODAYAM VIDYAMANDIR  
ANNAMANADA

*[Signature]*  
MANAGER

VIVEKODAYAM VIDYAMANDIR  
ANNAMANADA - 680741  
*[Signature]*  
Authorized signatory

## TEST REPORT

Test Report No : CKL/21/U888

Date : 21-09-2021

- Name of Customer : Vivekodayam Vidya Mandir School
- Customer Address : Vivekodayam Vidya Mandir School, Annamanada
- Test Requisition No. & Date : LWE294 & 18-09-2021
- Date of Sample Received : 18-09-2021
- Sample Analysis Date : 18-09-2021 To 20-09-2021
- Sample Name : Well Water
- Sample ID : U888
- Quantity of Sample Received : 250 ml
- Sample Drawn by : The Customer
- Sample Condition : Received in 250 ml sterile bottle

Parameters	Unit	Result	Test Method
<i>E.coli</i>	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 F
Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 B
Fecal Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 E

Note: '< 1.8' is equivalent to 'Absent' as per Test method.

Total Number of Determination: 3 only

*Rajabkshk*

**PRINCIPAL**  
**VIVEKODAYAM VIDYAMANDIR**  
**ANNAMANADA**

*Bahm*  
**MANAGER**

**VIVEKODAYAM VIDYAMANDIR**  
**ANNAMANADA - 680741**  
*Beera*  
**Authorized signatory**