

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 358/21 dtd 30/09/2021

Date : 30/09/2021

It is certified that an inspection team headed by SHAJI J
Health Inspector Incharge. (Name of Officers
will designation) from FHC, Mambra, Dept. of Health Services (Name of
Department/Office) inspected the Vivekodayam Vidhya Mandir
School, Annamanada. V/134 (Name & Address of
the School) on 28/09/2021 and found that the Vivekodayam Vidhya
Mandir School, Annamanada. (Name of school has safe-
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year

Rajalekhy K

**VIVEKODAYAM VIDYAMANDIR
ANNAMANADA**

Signature with Seal : [Signature]

Name : SHAJI J

Designation : JHI - Gr 1

പി.എച്ച്.സി. മെമ്പർ ഇൻചാർജ്ജ്
പി.എച്ച്.സി. മെമ്പർ

To

The Manager
Vivekodayam Vidhya Mandir School
Annamanada.

(Name & Address of the Institution)

[Signature]
MANAGER

**VIVEKODAYAM VIDYAMANDIR
ANNAMANADA - 680741**



TEST REPORT

Test Report No : CKL/21/ U888

Date : 22-09-2021

- Name of Customer : Vivekodayam Vidya Mandir School
- Customer Address : Annamanada
- Test Requisition No. & Date : LW294 & 18-09-2021
- Date of Sample Received : 18-09-2021
- Sample Analysis Date : 20-09-2021 To 21-09-2021
- Sample Name : Well water
- Sample ID : U888
- Quantity of Sample Received : 1ltr
- Sample Drawn by : The Medical officer ,PHC Mambra
- Sample Condition : Received in 1 ltr Plastic bottle.

Parameters	Unit	Result	Specification	Test Method
Alkalinity as CaCO ₃	mg/ L	45.68	Max- 200	IS: 3025 Part 23
Calcium	mg/ L	Nil	Max- 75	IS: 3025
Chloride	mg/ L	12.44	Max- 250	IS: 3025 part 32
Fluoride	mg/ L	Not detected	Max- 1	IS: 3025 part 60
Hardness	mg/ L	Nil	Max- 200	IS: 3025 part 21
Iron as Fe	mg/ L	Not detected	Max- 0.3	CKL/ANL/WA-021
Nitrate as NO ₃ ⁻	mg/ L	2.20	Max- 45	IS: 3025 part 34
pH	-	7.43	6.5 – 8.5	IS: 3025 Part 11
Sulphate as SO ₄ ²⁻	mg/ L	Not detected	Max- 200	IS: 3025 part 24
Total Dissolved Solids	mg/ L	48	Max- 500	IS: 3025 part 16
Turbidity	NTU	< 2	Max- 5	IS: 3025 part 10
Acidity	mg/ L	4.24	-	IS: 3025 Part 22

The sample complies as per IS: 10500- 2012, with respect to the tested parameters.
Total Number of Determination: 12 only

Rajalathya K

PRINCIPAL
VIVEKODAYAM VIDYAMANDIR
ANNAMANADA

Bahm
MANAGER

Meesale
Authorized signatory
ANNAMANADA - 680741

Note: The test results relate only to the sample tested. The report shall not be reproduced except in full, without the written approval of the laboratory

Address: KINFRA Small Industries Park, Nalukettu road, Koratty-680309, Ph: 0480 2735837, Fax: 0480 2735737, E-mail: lab@carekeralam.com

TEST REPORT

Test Report No : CKL/21/U888

Date : 21-09-2021

- Name of Customer : Vivekodayam Vidya Mandir School
- Customer Address : Vivekodayam Vidya Mandir School, Annamanada
- Test Requisition No. & Date : LWE294 & 18-09-2021
- Date of Sample Received : 18-09-2021
- Sample Analysis Date : 18-09-2021 To 20-09-2021
- Sample Name : Well Water
- Sample ID : U888
- Quantity of Sample Received : 250 ml
- Sample Drawn by : The Customer
- Sample Condition : Received in 250 ml sterile bottle

Parameters	Unit	Result	Test Method
<i>E.coli</i>	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 F
Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 B
Fecal Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 E

Note: '< 1.8' is equivalent to 'Absent' as per Test method.

Total Number of Determination: 3 only

Rajalathas K

PRINCIPAL
VIVEKODAYAM VIDYAMANDIR
ANNAMANADA

Balram
MANAGER

VIVEKODAYAM VIDYAMANDIR
ANNAMANADA - 680741
Authorized signatory

Green

Note: The test results relate only to the sample tested. The report shall not be reproduced except in full, without the written approval of the laboratory

Address: KINFRA Small Industries Park, Nalukettu road, Koratty-680309, Ph: 0480 2735837, Fax: 0480 2735737, E-mail: lab@carekeralam.com