

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No. 168/2025Date : 28/06/2025

It is certified that an inspection team headed by Sanu V.G,  
Health Inspector (Name of Officers  
 with designation) from Health Services Department, Govt of Kerala  
 Department/Office) inspected the Vivekodayam  
Vidhya Mandir School, Annamanada (Name & Address of  
 the School) on 28/06/2025 and found that the Vivekodayam Vidhya -  
Mandir School, Annamanada (Name of school) has safe  
 drinking water facilities for the students and members of staff of the institution and is maintaining  
 the hygienic sanitation condition in the school building & the campus as per the norms  
 prescribed by the Central/State/U.T Govt.

The above valid for a period of one year (28/6/2025 to 27/6/2026)



Signature with Seal :

ഫാത്തിമ ഉത്തമപ്രകാശ്  
എ.എസ്.എസ്.എസ്.

Name :

SANU V.G.

Designation :

HEALTH INSPECTOR

To

The Administrator,  
Vivekodayam Vidhya Mandir School  
Annamanada

(Name &amp; Address of the Institution)

Sanu  
 PRINCIPAL  
 VIVEKODAYAM VIDYAMANDIR  
 ANNAMANADA

For Vivekodayam Vidhya  
 Annamanada

Manager

Babunij  
Babunij P.P.

## TEST REPORT

Test Report No : RA25-26/0391/Q0778

Date : 28-06-2025


Name of Customer : Vivekodayam Vidhya Mandir  
Customer Address : Annamanada, 680741,  
Date of Sample Received : 26-06-2025  
Sample Analysis Start Date : 26-06-2025  
Sample Analysis Completion Date : 28-06-2025  
Sample Name : Well water  
Sample ID : RA25-26/0391/Q0778  
Quantity of Sample Received : 3 L  
Sample Condition : Received in good condition  
Standard Referred : IS :10500  
Sample Drawn By : PHC, Mambra

Sl. No.	Parameters	Unit	Result	Specification	Detection Limit	Test Method
1	Chloride	mg/L	21.68	Max 250	-	IS 3025 Part 32
2	Nitrate as NO <sub>3</sub> <sup>-</sup>	mg/L	9.60	Max : 45	0.5	IS 3025 Part 34
3	Electrical Conductivity	µs/cm	146.3	-	-	APHA 24th edn.2519A
4	pH	--	6.70	6.5 - 8.5	-	IS 3025 Part 11
5	Residual free chlorine	mg/L	BDL	Min 0.2, if chlorinated	0.2	IS 3025 Part 26
6	Sulphate	mg/L	4.94	Max : 200	4.0	IS 3025 Part 24
7	Total dissolved solids	mg/L	86	Max : 500	-	IS 3025 Part 16
8	Total Hardness as CaCO <sub>3</sub>	mg/L	8.12	Max:200	-	IS 3025 Part 21
9	Turbidity	NTU	< 2	Max : 5	-	IS 3025 Part 10
10	Alkalinity as CaCO <sub>3</sub>	mg/L	51.25	Max:200	-	IS 3025 Part 23
11	Calcium as Ca	mg/L	1.62	Max : 75	-	IS 3025 Part 40
12	Colour	Hazen	< 5	Max : 5	-	IS 3025 Part 4
13	Iron as Fe	mg/L	0.08	Max : 0.3	0.0005	CKL/ANL/WA-021

The sample complies as per IS: 10500- 2012, with respect to the tested parameters.

Total No of Determinants : 13

.....End of Report.....

  
Principal  
Vivekodayam Vidhya Mandir



  
Principal  
VIVEKODAYAM VIDYAMANDIR  
ANNAMANADA

  
Authorized Signatory  
BASIL ELDHO  
TECHNICAL MANAGER

Note : The test result relate only to the sample tested or sampled by the Laboratory. The report shall not be reproduced except in full, without the written approval of the laboratory. Perishable samples will be stored till end of analysis and non-perishable sample for 15 days.

Address : KINFRA Small Industries Park, Nalukettu Road, Koratty - 680 309, Ph : 0480 2735737, 5837 , E Mail : [info@carekeralam.com](mailto:info@carekeralam.com)

## TEST REPORT

Test Report No : RA25-26/0391/Q0778

Date : 27-06-2025

Name of Customer : Vivekodayam Vidhya Mandir  
Customer Address : Annamanada, 680741,  
Date of Sample Received : 26-06-2025  
Sample Analysis Start Date : 26-06-2025  
Sample Analysis Completion Date : 27-06-2025  
Sample Name : Well water  
Sample ID : RA25-26/0391/Q0778  
Quantity of Sample Received : 3 L  
Sample Condition : Received in good condition  
Standard Referred : IS :10500  
Sample Drawn By : PHC, Mambra

Sl. No.	Parameters	Unit	Result	Specification	Test Method
1	Escherichia coli (MF)	Present or Absent/ 100 ml	Absent	Absent	ISO 9308-1:2014
2	Total Coliform (MF)	Present or Absent/ 100 ml	Absent	Absent	ISO 9308-1:2014

The sample complies as per IS: 10500- 2012, with respect to the tested parameters.

Total No of Determinants : 2

.....End of Report.....

*Bahm*  
*Bahm*

*Shree*  
VIVEKODAYAM VIDYAMANDIR  
ANNAMANADA

*Supriya*  
Authorized Signatory  
**KRISHNA PRIYA K**  
Microbiologist

Note : The test result relate only to the sample tested or sampled by the Laboratory. The report shall not be reproduced except in full, without the written approval of the laboratory. Perishable samples will be stored till end of analysis and non-perishable sample for 15 days.

Address : KINFRA Small Industries Park, Nalukettu Road, Koratty - 680 309, Ph : 0480 2735737, 5837 , E Mail : [info@carekeralam.com](mailto:info@carekeralam.com)